

POLICY NO. 430

LINE EXTENSION AND CONDITIONS OF SERVICE FOR IRRIGATION

I. OBJECTIVE

PCRPPD will construct proposed line extensions and service upgrades for irrigation services and the customer will make a contribution in aid to construction.

II. GENERAL PROVISIONS

Construction costs shall include, but are not limited to, materials, equipment, transformers, meter, labor-including overheads, and right of way clearing.

III. NEW CONSTRUCTION

Except as otherwise excluded, PCRPPD shall contribute to the costs for the construction of new irrigation services and line extensions up to an Allowable Investment Limit (AIL). Any construction costs over the AIL shall be paid by the customer as a Contribution in Aid to Construction (CIA).

The Contribution in Aid to Construction (CIA) will be billed in two installments. The non-refundable initiating CIA will be due before the service is initiated, along with a contract for service. The second CIA installment will be billed upon completion of construction as follows:

Payable upon service initialization	
Single phase Nonrefundable ICIA	\$2,000.00 (per service)
Three phase Nonrefundable ICIA	\$4,500.00 (per service)
Payable upon completion of construction	
Single phase/Three phase	\$100.00 (Per HP)

The nameplate horsepower of the total motor will be used to determine the AIL and CIA. Minimum horsepower billing will be 5 HP for a single-phase service and 15 HP for three phase service.

PCRPPD will furnish all material and labor to construct overhead lines to the safest and most practical point nearest the customer property. All construction beyond the county right-of-way will be the responsibility of the customer. Changes after construction is complete will follow service upgrade guidelines.

IV. SERVICE UPGRADES

Service upgrades or added horsepower to existing irrigation services that are older than five years will follow the guidelines below. Any request requiring line extension will follow new service guidelines. Service upgrades to an existing service that is less than five years old, the CIA will be the greater of the below or the increased horsepower added to the original new construction contribution.

Upgrade single phase to three phase	Estimated construction costs less AIL \$110 per HP
Transformer/Voltage changes	\$1,250.00 per installation

V. SERVICE TERRITORY

When a customer requests service that is outside of PCRPPD service area the following conditions must be met:

- The land must be adjacent to PCRPPD service area boundary or adjacent to a service that has been waived previously.
- The customer must receive approval from the certified service provider, allowing PCRPPD to complete a Nebraska Power Review Board Consent and Waiver form.
- The CIA shall be one and one half (1.5) times the CIA for services within PCRPPD certified service area.

VI. SERVICE/LINE RELOCATIONS

Customer requests for line relocation will be at the sole discretion of PCRPPD, with public safety, operation, and maintenance of the relocated facilities the primary considerations.

- When a customer requests the replacement of existing overhead primary line with secondary underground, PCRPPD will remove the overhead primary line at its expense, and the customer will be responsible for the entire cost of the replacement secondary underground, fuse boxes, and switches.
- If line relocation results in no system betterment, the customer will pay for the entire cost of relocation.
- When a customer requests to abandon the current service location and move service to new location, the customer may be responsible for the entire cost of relocation.
- AIL will be applied to any line relocation resulting in increased service load.

VII. MISCELLANEOUS

PCRPPD reserves the right to review and modify the line extension contribution in aid to construction (CIA) amount to reflect the service characteristics of the service.

All line extensions exceeding one-half mile will be pre-approved by the board of directors.

The customer shall be responsible for applying for any electrical inspection of the customer facilities and shall furnish satisfactory inspection before service will be energized.

The customer shall furnish, install, and maintain all poles, wires and equipment installed beyond the point of delivery, which shall be defined as all equipment on the load side of the meter.

PCRPPD will furnish single phase or three phase at available secondary voltages. Motors having a rated capacity of less than fifteen horsepower will be connected single phase.

All motors over 10 HP will be installed with an appropriately sized capacitor. Accounts that do not comply with Section 10 of the "Irrigation Agreement for Electric Service" and do not have secondary capacitors installed will be billed \$2.50 per billable horsepower as a penalty and will be billed each irrigation season that the capacitors are not installed.

Prior to construction, the customer will be responsible for removal of all trees and brush that will hinder construction.

VIII. RESPONSIBILITY

The General Manager shall be responsible for the administration of this policy.

APPROVED BY THE BOARD OF DIRECTORS

EFFECTIVE DATE: 1/1/1990

DATE APPROVED: 9/8/1989

REVISED: 11/8/2005, 8/8/2006, 8/8/2008, 6/8/2010, 8/8/2012, 9/9/2013, 9/8/2022

REVISED: 9/8/2023

ATTEST: _____