

POLICY NO. 430

LINE EXTENSION AND CONDITIONS OF SERVICE FOR IRRIGATION

I. OBJECTIVE

The PCRPPD will construct proposed extensions for irrigation service and the Applicant or Owner will make a contribution in "Aid to Construction" payable in advance of construction.

II. PROVISIONS

1. For all new construction after August 8, 2012 "Aid to Construction" will be as follows:
 - a. Single phase \$1,750.00
 - b. Three phase \$1,750.00 per service plus \$65.00 per horsepower
 - c. The nameplate Horsepower of the motor will be used to determine the "Aid to Construction".

With the above "Aid to Construction", the PCRPPD will furnish all material and labor to construct overhead lines to the safest and most practical point nearest the landowners property. All construction beyond the county right-of-way will be the responsibility of the customer.

2. When adding horsepower to existing services that are older than five years and that PCRPPD must make changes from single phase to three phase, change the transformer and/or meter loop capacity, the "Aid to Construction" will be one of the following:
 - a. Single phase to three phase \$1,750 plus \$25.00 per added horsepower.
 - b. Single phase to three phase requiring conversion of distribution line more than 300' \$1750.00 plus \$65.00 per added horsepower.

- c. Transformer changes \$25.00 per added horsepower.
 - d. Transformer changes, voltage up rates \$500.00 per installation
3. When a customer requests service that is outside of the PCRPPD service area the following conditions must be met:
- a. The land must be adjacent to the service area boundary or adjacent to a service that has been waived previously.
 - b. The customer must provide the PCRPPD with a "Consent and Waiver form from the "Certified" service provider.
 - c. The "Aid to construction" shall be 1.5 (one and one half) times the rate for services in the certified service area.

When adding horsepower to existing services that is less than five years old the contribution will be the greater of the above costs or the increased horsepower added to the original new construction contribution.

The customer shall furnish, install and maintain all poles, wires and equipment installed beyond the point of delivery, which shall be defined as all equipment on the load side of the meter.

PCRPPD will furnish single phase or three phase at available secondary voltages. Motors having a rated capacity below fifteen horsepower will be connected single phase. All motors over 10 hp will be installed with an appropriately sized capacitor.

All line extensions that will exceed \$50,000.00 must be approved before construction is begun.

The contribution in "Aid to Construction", shall be payable to the PCRPPD prior to any construction.

On existing installations, where a consumer wants the existing line removed and replaced with underground, the existing line will be removed at no cost to the consumer and the consumer will be responsible for the entire cost of the underground, fuse boxes, and switches.

The applicant will be responsible for removal of all trees and brush that will hinder construction or operation on property that he owns, leases or rents, prior to construction.

Accounts that do not comply with Section 10 of the Irrigation Agreement for Electric Service and do not have secondary capacitors installed will be billed \$2.50 per billable horsepower as a penalty. Such penalty will be billed each irrigation season that the capacitors are not installed.

III. RESPONSIBILITY

The General Manager shall be responsible for the administration of this policy.

APPROVED BY THE BOARD OF DIRECTORS

EFFECTIVE DATE: 1/1/1990

DATE APPROVED: 9/8/1989

REVISED: 11/8/2000

REVISED: 11/8/2001

REVISED: 10/5/2004

REVISED: 11/8/2005

REVISED: 8/8/2006

REVISED: 8/8/2008

REVISED: 6/8/2010

REVISED: 8/8/2012

REVISED: _____

ATTEST: 